

## PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM

REGION		COUNTY	ID-NUMBER	DATE
4		18		4-15-86
STAFF		INSTALLATION: (X) 1. New Installation ( ) 2. Repair to Existing System		
004				
Type of System: (X) 1. Standard ( ) 3. Chapter 301 ( ) 2. Alternating ( ) 4. Other				
For: (X) 1. Residential: No. B/R 3 ( ) 2. Commercial/Industrial; Gal/Day _____				
Evaluation based Upon: ( ) 1. Soil Typing by Soil Scientist (X) 2. Soil Percolation Tests ( ) 3. Other				
Permeability Rate _____				

Issued to: Andy Gloss  
Owner, Developer, Contractor, Installer, Etc.


To be constructed by: John Link  
(Installer)

Construction of a subsurface sewage disposal system is hereby authorized at:  
Lot 60 Shadownmont  
(No. and street; Subdivision name and lot no.)

Such a system shall consist of a septic tank of 900 gals.  
with 230 linear feet in 3 trenches,  
16 inches wide, and 24 deep  
or \_\_\_\_\_

The recipient of this permit agrees to construct or have constructed the system in accordance with the rules and regulations under the authority of TCA 53-2054. The recipient must notify the local health authority when the system is ready for inspection. If any part of system is covered before being inspected and approved, it shall be uncovered by the recipient of the permit at the direction of the local health authority.

\_\_\_\_\_ Date 4-15-80  
 (Signature of Recipient-Owner, Developer, Contractor, Etc.)  
 Issued at \_\_\_\_\_, Tennessee in the County of Craig  
 By P. Webb Date 4-15-80  
 (Local Health Authority)



Inspected By \_\_\_\_\_ Local Health Authority  
Date \_\_\_\_\_ 7-15-80

Construction Approval: ☒ 1. Yes      ☐ 2. No

No. of Visits: 3

Time