


Approval is hereby granted for lot 3 defined as Crystal Springs Ph III, Putnam County, Tennessee as being suitable for subsurface sewage disposal (SSD) with the listed or attached restrictions.

Prior to any construction of a structure, mobile or permanent, the plans for the exact house/structure location must be approved and an SSD system permit issued by the Division of Water Resources. Water taps; water lines, underground utilities and driveways should be located at side property lines unless otherwise noted.

 John Smith ESI 10-15-2020  
Environmental Scientist Date  
Division of Water Resources

Approval is based on soil conditions suitable for installation of Subsurface Sewage Disposal Systems and does not constitute approval of building sites.

Lot 3 is approved for installation and duplication of conventional subsurface sewage disposal systems to serve an estimated house size of 3 (three) bedrooms.

The size, number of square feet, design, and location of the proposed dwelling may further affect the number of bedrooms for which a permit may be issued.

Lot 3 is approved for use with utility water only.

All underground utilities and driveways must enter along the property lines.

Lot 3 will require a pump system to transfer septic tank effluent to areas of the lot with suitable soil conditions for disposal.

Shading on the lot represents an area reserved to be used for the installation of the primary and duplicate subsurface sewage disposal systems, and shall be used for no other purpose such as house location, other structure location, buried utilities, driveways, swimming pools, etc. or use which would conflict with the REGULATIONS TO GOVERN SUBSURFACE SEWAGE DISPOSAL in Tennessee. Modification of the shaded area may be considered, provided sufficient shaded area is maintained.

Scale  
1" = 50'

